



### **Shower Liner Test Certification - All Systems**

The Virginia Construction Code, The Virginia Residential and The Virginia Plumbing Code requires a shower liner test be conducted to ensure that the shower floors and receptors are made watertight. The test requires the following:

1. The floor receptor area shall be filled with potable water to a depth of not less than two inches measured at the threshold.
2. Where a threshold of at least two inches does not exist, a temporary threshold shall be constructed to retain water in the lined floor to a level not less than two inches deep measured at the threshold.
3. The water shall be retained for a test period of not less than 15 minutes and there shall be no evidence of leakage.

Persons installing a shower system and installing the shower drain assembly shall provide this completed certification to the Building Inspector at final inspection, that the above noted shower liner test has been performed in accordance with the local Virginia Building Codes and per the product manufacturers specification (whichever is the most restrictive testing method).

I hereby certify the installation and liner test of the shower system was performed by persons trained and/or proficient in the installation of such systems in accordance with the test as required by the local Virginia Building Codes and the product manufacturers specifications:

Permit Number: \_\_\_\_\_ Job Address: \_\_\_\_\_

Phone #: \_\_\_\_\_ E-Mail: \_\_\_\_\_

Signature of Contractor/Owner: \_\_\_\_\_ Date: \_\_\_\_\_

---

#### **Official Use Only**

Approved By: \_\_\_\_\_ Date: \_\_\_\_\_