



COMMONWEALTH of VIRGINIA

M. Norman Oliver, MD, MA
State Health Commissioner

DEPARTMENT OF HEALTH

OFFICE OF DRINKING WATER

Richmond Field Office

Madison Building
109 Governor St., Ste
UB23 Richmond, VA
23219
Phone: 804-864-7409
Fax: 804-864-7520

SURFACE WATER TREATMENT PLANT SANITARY SURVEY REPORT

October 5, 2020

To: Ms. Rosemary Green, Deputy Director
Richmond Water Treatment Plant
3920 Douglasdale Road
Richmond, Virginia 23221

SUBJECT: CITY OF RICHMOND
Waterworks: Richmond Water System
PWSID: 4760100

Survey Date: 08/25/2020
Present at Survey: Doug Towne and others
Future Sampling Requirements: See attached

As a result of the sanitary survey noted above, the Department offers the following:

1. Comments from previous inspections:
 - a. DPU is continuing their internal cross-connection control project (re-piping and labeling).
UNRESOLVED – Plant [REDACTED] is complete and some of Plant [REDACTED] is complete. Maintenance has been addressing on-going items.
 - b. Perform a tracer study of the finished water basins with the aerators now removed.
UNRESOLVED- study postponed indefinitely.
 - c. The sludge lagoon is starting to fill up again. Prioritize your current efforts to get a contract for solids removal.
RESOLVED- Activities to start soon. Conducting on an as-needed basis
 - d. Sign, date, and return the attached Bacteriological Sample Siting Plan (BSSP) within 30 days of the date of this letter, or the City of Richmond may be deemed to be in violation of the *Waterworks Regulations* for not having an approved BSSP that complies with the Revised Total Coliform Rule. I brought a copy of the BSSP to the inspection and requested that someone sign it, but thus far a signed copy has not been returned to me.
UNRESOLVED- WTP indicated that should be done by either management or lab personnel. Copy provided to Lab Operations Manager via email (September 24, 2020) to review. **Please submit a signed copy of the BSSP by October 24, 2020 for our review and approval.**
 - e. The filter appurtenances should be calibrated at least once per year, and once per quarter is recommended. We understand that they were last calibrated on July 25, 2017. Please schedule them to be calibrated in the near future.

RESOLVED- Appurtenances calibrated 10/31/19. Please schedule to occur annually.

Ms. Rosemary Green, Deputy Director


Page 2

2. Comments from this inspection:

- a. The population served has remained at 197,000 residents for the past several years and may need to be re-evaluated based on current population. The results of the 2020 census may be a good source of information, once released.
- b. Please ensure filter drop tests, rise tests, and expansion tests are conducted on a routine frequency.
- c. Please ensure reagents in the lab are not expired. Expired reagents can be labeled "For Training Purposes Only", if desired for use as training devices.
- d. Richmond WTP and all associated staff should be commended for their hard work as essential workers during the 2020 COVID-19 pandemic. Potable water is critical for good hygiene and prevention of diseases and Richmond DPU has met the challenging times faced by this pandemic.

Our web site, www.vdh.virginia.gov/odw, contains helpful information and links for owners and operators. Owners can reach us during non-business hours to report emergencies at 866-531-3068; since this number is strictly for waterworks use only, please do not distribute it to customers or anyone outside your agency, company, or organization.

Survey By:



James Reynolds, P.E., Field Director

Enclosure(s):

1. Chemical Schedule (CS)
2. Sanitary Survey Report (SS)

ec/enc: Mr. Doug Towne, Acting Operations Superintendent (CS, SS) ✓
Mr. Roy Ritt, Maintenance Manager (CS, SS)
Richmond City Health Dept., attn: Environmental Health Manager (CS, SS)
VDH, ODW - Central Office (CS, SS)

ec: Mr. Calvin Farr, Director

cc: Mayor Levar Stoney, City of Richmond

Chemical Schedule for 4760100 RICHMOND, CITY OF

EP001 [REDACTED] PS - ENTRY POINT NO 1
 EP001 [REDACTED] PS

<u>Group</u>	<u>Last Sample</u>	<u>Freq.</u>	<u>Next Sample</u>	<u>Comments</u>
Fluoride Split	4/9/2015	1	5/9/2015	
SOCs - Carbamates	2/18/2020	3	5/18/2020	
SOCs - Diquat	2/18/2020	3	5/18/2020	
SOCs - Semi-Volatile Organic Chemical	2/18/2020	3	5/18/2020	
SOCs - Volatile Fumigants	3/31/2020	3	6/30/2020	
Cyanide	2/27/2012	108	2/27/2021	
Inorganics	6/30/2020	12	6/30/2021	
Metals	6/30/2020	12	6/30/2021	
Nitrate + Nitrite (Combined)	6/30/2020	12	6/30/2021	
VOC	6/30/2020	12	6/30/2021	
Radiological	8/17/2018	72	8/17/2024	

Waivers

	<u>Begin</u>	<u>End</u>
CYANIDE2019	1/1/2011	12/31/2019
CYANIDE2028_B	1/1/2020	12/31/2028

IN001 RAW WATER INTAKE
 RW001 RAW WATER INTAKE

<u>Group</u>	<u>Last Sample</u>	<u>Freq.</u>	<u>Next Sample</u>	<u>Comments</u>
TOC-Alkalinity (Raw)	4/15/2015	1	5/15/2015	

TP001 RICHMOND WTP
 UP001 TOC COMB. FILTER EFF

<u>Group</u>	<u>Last Sample</u>	<u>Freq.</u>	<u>Next Sample</u>	<u>Comments</u>
TOC-Low (Finished)	4/15/2015	1	5/15/2015	

DS001 DISTRIBUTION SYSTEM
 DB002 [REDACTED]

<u>Group</u>	<u>Last Sample</u>	<u>Freq.</u>	<u>Next Sample</u>	<u>Comments</u>
HAA5	7/7/2020	3	10/7/2020	Sample: Jan-Apr-Jul-Oct
TTHM	7/7/2020	3	10/7/2020	Sample: Jan-Apr-Jul-Oct

DB006 [REDACTED]

<u>Group</u>	<u>Last Sample</u>	<u>Freq.</u>	<u>Next Sample</u>	<u>Comments</u>
HAA5	7/7/2020	3	10/7/2020	Sample: Jan-Apr-Jul-Oct
TTHM	7/7/2020	3	10/7/2020	Sample: Jan-Apr-Jul-Oct

DB007 [REDACTED]

<u>Group</u>	<u>Last Sample</u>	<u>Freq.</u>	<u>Next Sample</u>	<u>Comments</u>
HAA5	7/7/2020	3	10/7/2020	Sample: Jan-Apr-Jul-Oct
TTHM	7/7/2020	3	10/7/2020	Sample: Jan-Apr-Jul-Oct



<u>Group</u>	<u>Last Sample</u>	<u>Freq.</u>	<u>Next Sample</u>	<u>Comments</u>
HAA5	7/7/2020	3	10/7/2020	Sample: Jan-Apr-Jul-Oct
TTHM	7/7/2020	3	10/7/2020	Sample: Jan-Apr-Jul-Oct

50 Lead and Copper Samples due 6/25/2022

Data on this report is calculated from the date the last sample was collected and does not factor modifications to the monitoring requirements that may have been established since that last collection period. Current and future monitoring schedules should be reviewed in SDWIS to verify the accuracy of this report.

**VIRGINIA DEPARTMENT OF HEALTH
OFFICE OF DRINKING WATER
SUBPART H SYSTEM SANITARY SURVEY REPORT**

SUBJECT: CITY OF RICHMOND
WATERWORKS: Richmond City System
PWSID: 4760100

PART I - SYSTEM BACKGROUND & FINDINGS

GENERAL INFORMATION

Owner Name: City of Richmond Department of Public Works	Waterworks Class: 1
Type of Waterwork: Community	
Contact Name: Ms. Rosemary Green, Deputy Director of Public Utilities	
Contact Address: 3920 Douglasdale Road., Richmond, Virginia 23221	
Contact Phone Number: (804) 839-0294	

DO License Class: 1	DO Has Required License: Yes
DO Legal Name: Douglas Towne	DO License No.: 1955005005- exp. 2/2021

Inspection By: James Reynolds	Inspection Date: 08/25/2020 <i>je 10/15/2020</i>
Time Spent: 5 hours	Last Inspection Date: 05/24/2019
Date to Reviewer: 09/28/2020	Reviewed by/Date: <i>YD</i> 10/1/2020 4:48:14 PM EDT
Date to Reviewer:	Reviewed by/Date:
Inspection Type: Routine	
Present at Inspection: Doug Towne	
Facilities Inspected: Treatment plant, pre-sed/ lagoon	

Operation Permit Effective Date: 12/27/96	Waterworks Description Sheet Date: 11/14/96
Permit Up-to-Date No ¹	Description Sheet Up-to-Date No ¹
No. Connections: about 65,604 (4,000 inactive)	Population Served: about 197,000 residents ²
Avg. Daily Production: 70.08 MGD (6/19-7/20)	Operation Permit Capacity: 132 MGD
Exceeds 80% Operation Permit Capacity? (max. 3 consecutive months) No If yes, explain:	
Treatment Provided: Coagulation, sedimentation, filtration and final disinfection.	
SDWIS Inventory Information Current: Yes, verified 08/24/2020	

Comments: 1. Many changes have been made to facilities and capacity.
2. Population served should be verified and updated as necessary. 2020 census results may be a good time to re-evaluate

COMPLIANCE HISTORY

Shaded boxes	indicate a potential Significant Deficiency	
TOTAL COLIFORM RULE		
• BSSP Approved:	Not yet	(1)
• # of routine samples/monitoring period & frequency	120 per month	
• Is plan current & appropriate for dist. system & pop.?	Yes	
• Is monitoring frequency correct?	Yes	
• Rotates and uses approved sites?	Yes	
• Measures chlorine residual for all samples, if added?	Yes	
• RTCR Level 1 or 2 Assessments since last Survey?	No	
DDBP RULES (Community & NTNC)		
• Monitoring Plan approved and current?	Yes	02/26/13
• Monitoring frequency required:	4 sites per quarter	
• Operational Evaluation Level exceeded?	No	
ESWT RULES		
• Disinfection Profile with MOR or available for review?	With MOR	
• LT2 Rule - Round 1	Bin 1	9/24/08
• LT2 Rule - Round 2	Bin 1	5/2/17
• Treatment upgrades required?	None	
• If yes, describe:		
PHASE II/V RULE		
• Waivers current for all entry points?	Yes	
CONSUMER CONFIDENCE REPORTS		
• Final report issued by deadline?	Yes (06/17/20)	
• Certification Statement Received?	Yes (07/13/20)	
LEAD & COPPER RULE		
• Materials Survey/Sampling Plan Approved:	Yes	7/1/93
• Water Quality Parameter (WQP) monitoring required?	Yes	
○ If yes, WQPs meet quality and freq. reqmnt?	Yes	
• Have Action Levels (90%) been exceeded in past?	Yes	
○ If so, when?	1992	
• Public Education requirements met if required?	Yes	
• Optimized Corrosion Control Treatment (OCCT) required?	Yes	
○ Is OCCT monitoring performed and acceptable?	Yes	
• All consumer notice requirements met?	Yes (last done 10/11/19)	
Comments: 1. The revised BSSP has not been signed by the owner's representative. 2. Stage 2 DBP dates on previous reports were conflicting and did not match with database date. Last signed/approved copy in files as 02/26/13. Date in database updated to reflect.		

Y = Yes; N = No; NA = Not Applicable; NI = Not Inspected; None = None; OK = Acceptable

CROSS-CONNECTION CONTROL PROGRAM		DATE
• Approved:	Yes	8/7/06
• Inspected Records This Visit	No ¹	
○ Program Active	NI	
○ Satisfactory	NI ²	
MONTHLY OPERATION REPORTS		
• All submitted for past 12 months	Yes	
• Operational treatment parameters monitored?	Yes	
• All required data reported?	Yes	
EMERGENCY MGMT. PLAN for Extended Power Outage		DATE
• Verification received?	Yes	7/14/05
• Current?	Yes	
SOURCE WATER ASSESSMENT PERFORMED		
• Source: James River	Yes	2/12/02
ENFORCEMENT		
• Administrative/Consent Order in Effect:	None	
• Violations / Enforcement Actions Since Last Survey	None	
• Owner issued Public Notice as required?	NA	
• Active Corrective Action Plan?	None	
○ If yes, is waterworks on schedule?		
• SDWIS Violation & Enforcement Action, Public Notification data current?	Yes	
COMPLAINTS SINCE LAST INSPECTION		YES
• If YES, summarize: Normal variety of complaints.		
Comments:		

\ Y = Yes; N = No; NA = Not Applicable; NI = Not Inspected; None = None; OK = Acceptable

MONITORING HISTORY
See Attachment 1 with the owner's report.

¹ See Part C for additional questions

² Based on Part C questions

SUMMARY

Evaluation Category	Last Inspection	Next Inspection Due
Treatment, Monitoring, Reporting and Data Verification, Operator Compliance	08/25/20	08/25/21
Raw Water Source	08/25/20	08/25/21
Distribution, Cross Connection Control, Finished Water Storage, Pumps, Meter & Valve Vaults	09/19/18	09/19/21
System Management & Administration	09/19/18	09/19/21

PART II-A
UNIT PROCESS EVALUATIONS
 (Shading Identifies a Potential Significant Deficiency)

A. RAPID MIX

1. Number of units: see comment c. Number in service: see comment c.
2. Type of mixing provided:
3. Operable mixer available to meet mixing requirements Yes No N/A
4. If conventional units:
 - Variable speed control operational?
 - Evidence of vortexing? Yes No
 - Proper mixing obtained? Yes No
5. Chemicals being applied, point(s) of application:

Chemical Applied	Application Point	Feed Rate
CuSO ₄		
KMnO ₄		
Hypochlorite		
Powdered Activated Carbon		
Alum		
Coagulation Polymer		

6. Spare mixer provided? Yes No
7. General performance: satisfactory needs attention
8. Physical condition of unit: satisfactory needs attention

COMMENTS:

- a. When water temperature
- b. when needed, to control algae. Selection balances cost and DBP formation:
 - i. During warm weather is added. Was fed at time of inspection
 - ii. During cold weather (typically December-March)
- c. There are rapid mix units for each plant, but they are not used. was in service in each . The staff found they generally worked better than the rapid mix units, because the rapid mix blades sheared floc. The rapid mix units remain available for use, if needed.
 - i. See page 14 for comments about SCM.

B. FLOCCULATION/SLOW MIX

1. Number of basins: [redacted] Number in service: [redacted]
2. Mode of operation: series parallel NA
3. All mixers operational? Yes No
4. Operable mixers available to meet mixing requirements: Yes No
5. Variable speed control operational? Yes No NA
6. Tapered flocculation practiced? Yes No NA
7. Isolation of basins/continued plant operation? Yes No NA
8. Are proper baffles/compartments provided? Yes No
9. Evidence of vortexing/basin short-circuiting? Yes No
10. Overall floc formation: good fair poor undetectable
Floc type/appearance: pin floc fluffy sweepfloc other _____
11. Are polymers used? Yes No
12. General performance: satisfactory needs attention
13. Physical condition of unit: satisfactory needs attention

COMMENTS:

- Each of the [redacted] sedimentation basins has [redacted] flocculation basins. The [redacted] basins are both parallel and in series.
- Some mixing units were being refurbished

C. SEDIMENTATION

1. No. of basins provided: No. in operation:

2. Proper flow distribution between basins? Yes No

3. Signs of short circuiting/overloads? Yes No

4. Evidence of floc shear at stilling wall? Yes No

5. Floc carry-over observed? Yes No

6. Floc settleability: satisfactory needs attention

7. Sludge removal: manual mechanical

If manual: 2 times/year; last cleaned: Spring 2020; plan for next cleaning Fall 2020

If mechanical, is equipment operable: Yes No

Excessive sludge accumulation: Yes No

If "Yes", estimate sludge blanket depth:

8. Chemicals added, application point(s):

Chemical Applied	Application Point	Feed Rate (mg/l)
Caustic		
Chlorine		
Filter Polymer		

9. General performance: satisfactory needs attention

10. Physical condition of unit: satisfactory needs attention

COMMENTS:

- a. The new sludge removal system has been installed on all basins, and is performing well. The plate settlers continue to perform well.
- b. Some piles of sludge were observed where the vacuum collection heads pushed sludge to the side or where the heads can't reach. Not appreciable or seen to impact turbidity carry-over

D. FILTRATION

1. No. of filters provided: [redacted] No. in operation: [redacted]

2. Filter media: [redacted]

Date media last added or changed: 2005 / 2006

Frequency media depth checked: Periodically

Frequency operator checks filtration rate: monthly Date last checked 08/2020

Values observed for individual filters:

Filter No.	Effluent Turbidity (NTU)	Loading Rate (gpm/ft ²)
[redacted]	0.02-0.03 NTU	3.2 MGD (2.06 gpm/ft ²)
[redacted]	0.02-0.03 NTU	3.2 MGD (2.06 gpm/ft ²)

Design: [redacted] short term, see 3/13/02 letter}

Exceeds permitted rate? Yes No

Was filtration rate checked? Yes No

Filter Area + Gullet [redacted] Volume (per 6" drop) = [redacted]

3. Filter appurtenances operable and in good condition? Last Calibrated

All valves/controls (electrical PM#701): Yes No 10/31/19

Filter rate-of-flow controls (PM#1416): Yes No 10/31/19

Filter rate-of-flow indicator/recorder (#1416): Yes No 10/31/19

Loss of head indicator/recorder (PM#677): Yes No 03/08/19

Surface wash: Yes No NA

Air scour: Yes No NA

Backwash pump(s)/controls (PM#702): Yes No DNI

Backwash rate-of-flow indicator: (PM#702): Yes No DNI

4. Filter backwash practices:

Filter backwash based on plant established maximum values: Yes No

Filter backwash based on: [redacted] feet
 [redacted] hours
 [redacted] NTU
 particle counts [redacted] particles
 [redacted]

Average/maximum before backwash (May-July 2020):

head loss: [redacted] feet filter run times: [redacted] hours

turbidity: 0.021/0.06 NTU particles: n/a

Filter backwash observed? Yes No
Satisfactory? Yes No NA
Frequency operator checks backwash rate: Monthly Date last checked: 08/2020

5. Filter-to-waste practiced: Yes No NA

Is filter to waste at design filtration rate? Yes No
Average filter-to-waste (rewash) time:
Is turbidity monitored during filter-to-waste? Yes No NA
Criteria established for filter-to-waste duration: Set point
Are particles counted/monitored during procedure? Yes No

6. Is filter backwashed after any/all shutdowns? Yes No
If "No", does operator start filter with filter-to-waste after filter has been idle, before delivering flows to system? Yes No

9. General performance: satisfactory needs attention

10. Physical condition of units: satisfactory needs attention

COMMENTS:

1. WTP added [redacted] to existing data system, without an expensive system redesign. Data is normally captured, but reliability and redundancy were not provided. This has resulted in frequent missing and occasional incorrect data (skewing VOP summary).
 - a. WTP-wide SCADA project proceeding with installation – conduit laying and screen development are complete. The maintenance staff is hooking up the new PLC's and the new consoles, many filters completed.
 - b. [redacted]
2. Staff have been performing regular drop, rise and expansion testing.
 - a. Results of the drop and rise were satisfactory.
 - b. Results of the expansion testing show only 17-18 inches expansion at backwash rates of 22-26 MGD.
3. Some headloss indicators (Filters [redacted]) were offline for a brief period based on MORs. All back in service at time of inspection.
4. [redacted] A capital project is being discussed to fix this issue.
5. Media assessment was planned for the near future to determine if media replacement is necessary.
6. If a filter is sitting for an extended period, WTP will [redacted] before placing online.

E. FINISHED WATER FACILITIES

1. Clear well

Yes No
 Yes No N/A
 Adequate drain Yes No
 Screened vent(s) Yes No
 Watertight roof/cover Yes No
 Hatch(s) secure Yes No
 Viewing port with light Yes No
 Sediment present Yes No
 Last cleaned: _____ Plant in 2006 / Plant in 2007
 Physical condition: satisfactory needs attention

2. Filtered water pumps: Number provided/operable/in use: _____
 Pressure gauges provided/operable Yes No Not read psig
 Flow meter operable Yes No Not read MGD
 Physical conditions: satisfactory needs attention

3. Finished water pumps: Number provided/operable/in use: _____
 Pressure gauges operable 1/2/3) 95 _____ and 142 _____ psig Yes No
 Flow meter operable Yes No (See comments)
 Physical conditions: satisfactory needs attention

4. Is clearwell water level monitored/controlled? Yes No NA

5. Are level sensors operable? Yes No NA

6. Chemicals added, point(s) of application:

Chemical Applied	Application Point	Dose (mg/l)
Hypochlorite		
Ammonia		
Fluoride		
Lime		
Phosphate		
Caustic		

7. Approved device to isolate process water at treatment plant from distribution system?
 Plant RPZ devices tested annually. Yes No

COMMENTS:

- a) [REDACTED]
[REDACTED] A detailed description of the filterwells/clearwells is provided in the October 2003 special inspection report.
- b) Viewing ports (to the 'clearwell') are not routinely used by operators. The "water quality" can be observed in the aeration basins.
- c) Finished water [REDACTED] schematic is complicated, servicing several very different demands. This is why the pressures are so different and the flow is [REDACTED]
[REDACTED]
- d) [REDACTED]
- e) [REDACTED]
- f) [REDACTED] feed was offline due to maintenance. Awaiting replacement parts to complete maintenance.
Update: [REDACTED] feeders back online per email dated September 28, 2020.

F. CHEMICAL FEED FACILITIES – GENERAL

1. The following chemicals are fed at this facility:

Chemical	No. of Feeder/Pumps Available / In Service	Chemical	No. of Feeder/Pumps Available / In Service
<input type="checkbox"/> KMnO ₄		<input checked="" type="checkbox"/> chlorine	
<input type="checkbox"/> activated carbon		<input checked="" type="checkbox"/> ammonia	
<input checked="" type="checkbox"/> alum		<input checked="" type="checkbox"/> fluoride	
<input checked="" type="checkbox"/> polymer (coag. aid)		<input checked="" type="checkbox"/> phosphate	
<input type="checkbox"/> polymer (filter aid)		<input checked="" type="checkbox"/> lime	
<input checked="" type="checkbox"/> caustic		<input type="checkbox"/> other	

Chemicals certified to meet NSF Standard 60?

Yes No

2. Any chemical feed changes that could affect Pb/Cu monitoring?

Yes No

3. All feeders in good condition?

Yes No

Adequate ventilation provided?

Yes No

4. Adequate backflow prevention on solution water?

Non-potable, isolated by RPZ. Yes No

Anti-siphon devices on feed lines?

Yes No

Feeders calibrated on a regular basis? (recommend quarterly)

Yes No

Frequency operators calibrate feeders:

Pumps not calibrated

Date last calibrated:

NA

Frequency operators check calibrations:

Rate checked once/month

Date last checked:

08/2020, with drawdown tube

5. Adequate chemical storage area provided (space, spill prevention)?

Yes No

6. Is CORROSION CONTROL practiced at this facility?

Yes No

If Yes, indicate method(s):

pH/alkalinity adjustment

corrosion inhibitor

other: _____

7. Physical condition of chemical feed facilities:

satisfactory needs attention

8. Do any of the chemical storage or handling facilities offer potential for explosions?

Yes No

9. Other safety problems for the operators or public noted?

Yes No

Describe:

Comments:

- WTP is using interim [redacted] It is working well.

G. HYPOCHLORITE (The hypochlorite is fed to the applied water channels.)

- 1. Solution tank in good condition Yes No
- 2. Solution tank covered Yes No
- 3. Drain provided Yes No
- 4. Spill containment adequate Yes No
- 5. Stored away from organics and acids Yes No
- 6. Gloves, apron & eye protection Yes No
- 7. Eyewash/safety shower provided Yes No

H. FLUORIDE ACID

- 1. Weighing scale and recorder provided and in good condition Yes No
- 2. Gloves, apron & goggles provided Yes No
- 3. Chemical respirator, rated for acid use (SCBA) Yes No
- 4. Water meter/fluoride feed pacer/other control system provided, in good operating condition
 Yes No
- 5. Anti-siphon protection (Back pressure sustaining valve) Yes No
- 6. Feeder/metering pump operable and in good condition Yes No
- 7. Injection line in good condition Yes No
- 8. Separate feeder/storage room Yes No (for storage only)
- 9. Room ventilation adequate Yes No
- 10. Carboy/tank vented to outdoors Yes No
- 11. Carboy/tank openings sealed Yes No

Comments: Fluoride feeders offline for maintenance. Awaiting parts. **Update: Fluoride feeders back online per email dated September 28, 2020.**

I. OPERATIONAL/PERFORMANCE DATA

Constant Monitoring Equipment	Operable	Inline Reading	Bench Reading	Corresponds To Desk Unit
raw pH	Yes	7.62,7.69	7.5	Yes
flash mix pH	Yes	6.5,6.2	6.2	Yes
finished pH	Yes	7.4,7.6	7.7	Yes
raw turbidity	Yes	11.81, 12.83	13	Yes
sed basin 1-2 turbidity	Yes	0.27,0.29	0.3	Yes
sed basin 3-4 turbidity	Yes	0.35,0.41	0.4	Yes
		Inline Reading	SCADA Reading	Corresponds to Inline
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.03	0.03	Yes
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.03	0.03	Yes
filter turbidity	Yes	0.03	0.03	Yes
filter turbidity	Yes	0.03	0.03	Yes
filter turbidity	Yes	0.03	0.03	Yes
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.021	0.02	Yes
filter turbidity	Yes	0.03	0.03	Yes
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.03	0.03	Yes
filter turbidity	Yes	0.03	0.03	Yes
filter turbidity	Yes	0.02	0.02	Yes
filter turbidity	Yes	0.05	0.05	Yes
finished turbidity	Yes	0.156	0.16	Yes
finished chlorine	Yes	4.41	4.43	Yes

1. At time of inspection (Check last lab bench instrument values)

Parameter	RAW Freq/Results	APPLIED Freq/Results	FINISHED Freq/Results
Alkalinity (mg/L as CaCO ₃)	████ 44	████ 16,16	N/A
Hardness (mg/L as CaCO ₃)	N/A	N/A	N/A
Temperature °C	████ 23.3	N/A	N/A
Fluoride (mg/L)	N/A	N/A	████ Offline
Iron (mg/L)	N/A	N/A	N/A
Manganese (mg/L)	As needed	N/A	████
Phosphate (mg/l)	N/A	N/A	1.58, 1.46 (phosphate)

Plant flow at time of inspection: Raw Water 76.8 MGD Filtered/Finished Water 67.9 MGD (daily totals)

Comments:

J. OPERATIONAL/LABORATORY STAFF MONITORING PROCEDURES

1. Hours plant is operated per day: [REDACTED]
2. Designated Operator (DO) - Hours/Day present: [REDACTED]

List all operators and their classification that work at this facility:

Name (as shown on license)	License Class	License Number	Expiration Date	Remarks
Leroy A. Rice, Jr.	1	1955001901	2/28/21	Operations
Douglas Park Towne	1	1955005005	2/28/21	DO-Acting Super II
Ronnie T. Bartholomew	1	1955004688	2/28/21	Chief Operator
James E. Baty	1	1955003876	2/28/21	Chief Operator
Jason D. Russell	1	1955006243	2/28/21	Chief Operator
Robert Arnold Thompson	1	1955003216	2/28/21	Chief Operator
William Jae Wright	1	1955006328	2/28/21	Chief Operator
Toby Michael Bryant	1	1955005487	2/28/21	Sr Operator
Kevin L. Coleman	1	1955000404	2/28/21	Sr Operator
Bradley Morgan Halsey	1	1955006781	2/28/21	Sr Operator
Matthew D. Hicks	1	1955004513	2/28/21	Sr Operator
Thomas Stanley Marsh	1	1955006269	2/28/21	Sr Operator
Donald Jackson Murray	1	1955005058	2/28/21	Sr Operator
Travis Parker	1	1955003607	2/28/21	Sr Operator
Floyd M. Quesenberry	1	1955003652	2/28/21	Sr Operator
Rembert J. Wallace	1	1955004689	2/28/21	Sr Operator
Charles Gary Watts III	1	1955006639	2/28/21	Sr Operator
Jerry Wayne White Jr.	1	1955004976	2/28/21	Sr Operator
Zachary Andrew Fisher	1	1955006867	2/28/21	Sr Operator
Shaka Ade Smith, Sr.	1	1955007418	2/28/21	Sr Operator
Bill Whitaker (trainee)				Sr Operator
Jermaine Murray (trainee)	2	1955007750	2/28/21	Sr. Operator

Is the staffing in accordance with the Waterworks Regulations? Yes No

*Ricky Hatfield has changed positions. Doug Towne was Acting Superintendent at time of inspection, however interviews were pending for the position.

3. How are operating decisions made and communicated? The shift supervisors (Class 1 operators) are authorized to make operating decisions, but must abide by the operating parameters in the SOP's. They record any operational changes on the daily log sheet, and verbally inform the shift supervisor for the next shift of any operational changes that they made. The plant superintendent learns of operational changes by reading the daily log sheet each day.

Are there criteria and procedures established for plant shut down in case of unit process failure or upset or in event of significant overall quality degradation? Yes No

4. RECORDS RETENTION in accordance with *Regulations*? Yes No

5. Are daily log/data sheets readily available? Yes No

Were these daily log/data sheets reviewed? Yes No

Are the daily log/data sheets adequate? Yes No NA
Is the frequency of operational data collection adequate? Yes No NA
Are there any obvious problems noted with the log entries? Yes No NA

Comment:

6. How is the COAGULATION PROCESS controlled?

██████████ Pilot Filter
██████████ Jar Tests

Were coagulation control procedures observed / discussed? Yes No
Were the procedures adequate? Yes No NA

7. Is equipment in good condition?

pH meter Yes No
Jar test machine Yes No
██████████ Yes No NA
Pilot filters Yes No NA
Streaming current monitor Yes No NA reading (if applicable): 1.2 (avg)
Particle counter/monitor Yes No NA

8. What is the frequency of (combined) FILTER EFFLUENT TURBIDITY monitoring?

___ times per shift continuous

Is this frequency adequate (at least every 4 hours)? Yes No NA
Are continuous monitoring units operational? Yes No NA
Are the on-line (continuous) units calibrated at least quarterly? Yes No NA
Do continuous monitor readings correspond to desk-top unit readings? Yes No NA
Does each filter effluent have an individual continuous turbidity monitor? Yes No
Does the filter effluent turbidity monitoring system have alarm set points? Yes No

Alarm set point(s): ██████████ Alarm type: SCADA alert

Is data recorded at least every 15 minutes? Yes No
Is data kept for 3 years? Yes No
Desk-top turbidimeter manufacturer: ██████████ Model No. ██████████
Date last calibrated: 11/19/19
Calibration date posted: Yes No
Date bulb last changed: ██████████ Spare bulb on hand? Yes NA
Condition of cuvettes: Satisfactory
Primary standard used: ████████████████████

Expiration Date of primary standard: 3/21

Secondary standard used: None

Age of secondary standard: NA

Date secondary last compared to primary: NA

Turbidity-free water available? Yes No

9. Method of CHLORINE RESIDUAL monitoring: [REDACTED]
Continuous residual monitor operational? (required for Population > 3,300) Yes No NA

Does each analyzer have local readout and continuous recording (SCADA) Yes No

Is data recorded at least every 15 minutes? Yes No

Is an alarm activated when chlorine concentration is outside normal operating range? Yes No

Applied Set limits: Min: [REDACTED] Max: [REDACTED]

Finished Set limits: Min: [REDACTED] Max: [REDACTED]

Are grab samples collected at least weekly for routine calibration checks for each on-line analyzer? Yes No

Is a sample tap for grab samples located as close as feasible to where samples enter the on-line analyzer? Yes No

What method is used to analyze grab samples? [REDACTED]

If system serves ≤ 3,300, frequency of residual monitoring (Grab Sampling): N/A

Expiration date of colorimeter gel standards: DNI

Frequency of monitoring satisfactory? Yes No

Free chlorine residual measured and reported? Yes No

Calibration Checks performed? Yes No

If yes, Are results of calibration checks within the larger of +/- 0.1 mg/l or +/- 15%? Yes No

Are emergency calibration checks performed as soon as possible when an on-line chlorine analyzer indicates a large (≥50%) unexpected change? Yes No
 NA

Are records of calibration recorded and maintained for 3 years? Yes No

Do all chemical reagents and standards for on-line analyzers and grab sample methods have an unexpired shelf life? Yes No

Chlorine residual necessary to meet CT requirements: [REDACTED]

Location of measurement: [REDACTED]

Staff aware of the required minimum residual? Yes No

(WTP target of [REDACTED] exceeds minimum to meet CT)

Is this concentration being continuously met? Yes No

If No, is staff checking other parameters/taking appropriate steps to ensure CT requirements are being met on continuous basis? Yes No
 NA

10. Are adequate LAB EQUIPMENT AND REAGENTS available to run necessary operational tests? Yes No

Are reagents dated? Yes No

Are test procedures appropriate? Yes No

Are desk-top units calibrated at appropriate intervals? Yes No

Does plant have LABORATORY CAPABILITY for:

algae counts and identification? Yes No

threshold odor determinations? Yes No

iron and manganese analyses? Yes No

Overall appearance of laboratory: satisfactory needs attention

11. FLUORIDE test utilized: _____

Equipment in good condition? Yes No NA

Standards up-to-date? Yes No NA

Is a continuous analyzer provided? Yes No NA

Do continuous analyzer reading correspond to test kit readings? Yes No NA

Frequency of continuous monitoring unit calibration: _____ NA

12. Is CONTINUOUS pH monitoring equipment provided and in good condition? Yes No NA

Do continuous monitor readings correspond to desk-top readings? Yes No NA

Frequency of continuous monitoring unit calibration: _____ Weekly or as needed

13. Adequate BACKFLOW PREVENTION devices at sinks, etc. Air-vacuum breaker Yes No


COMMENTS:

- DPU has had successful coagulation as measured by VOP awards.
- DPU has requested eliminating the _____ devices as DPU controls their process with _____ meter readings. ODW has responded that _____ is required for _____
 - In 2016, DPU asked if they could move their _____ devices in _____ to the _____ after the _____. ODW responded this could be included as part of the project when the installation of the _____ is formalized, after 2018.
 - For clarification, regulations state that a jar test and ONE or more of the following means of controlling coagulation _____ potential, pilot filters, streaming current)
 - _____ currently used for trending purposes only, _____ meter is used to find approximate coagulation dosage requirements

K. WASTE HANDLING

1. Filter backwash, rewash, and settling basin wastewaters discharged to:
 lagoons holding tank/sand beds other _____
2. Ultimate discharge of waste flows: Lagoon sludge to landfill, lagoon supernatant recycled.
3. Provisions for water recycle to head of plant? Yes No
4. Is FILTER BACKWASH RECYCLE practiced? Yes No NA
Is recycle stream monitored for flow? Yes No* NA
Is recycle stream monitored for quality parameters? Yes No* NA
- *Recycled filter backwash that is not measured is a Significant Deficiency
Recycle Flowrate (total range): 0.9-1.71 MGD (August 2020)
% of Raw Water Flow (should be < 10%): 1-2% (August 2020)
Is approved treatment provided for recycle flows? Yes No* NA
If Yes, Describe: Lagoon sedimentation
* Recycled flow should be returned to the plant headworks. If additional approved treatment is not in service, it is a Significant Deficiency
VDH approval date: DPU submitted FBRR information 9/18/02
5. Are floor drains in chemical storage and feed areas separated from waste flow streams? Yes No NA

COMMENTS:

- a. 
- b. DPU has decided to remove sludge by annual contracts for one year's worth of accumulation.
(1) DPU planning on removing sludge from the lagoons in near future.

L. EMERGENCY POWER

- Portable generator connection(s). Identify generator supplier:
- Permanent equipment installed
- No Provisions

Fuel: [Redacted]

Generator Rating: [Redacted]

- % of Total Power Demand met [Redacted]
- Describe water production capability & critical elements supplied: [Redacted]

[Redacted]

[Redacted]

[Redacted]

Not read
Not determined

Fuel Tanks:

- Fuel tank a minimum of 50 feet from any well or 100 feet from intake Yes No
- Containment provided for fuel tank (tank in tank) Yes No
- Leak detection provided Yes No
- Fuel tank double walled Yes No
- Refueling protected from spills Yes No
- Evidence of fuel leaks Yes No

How often is the Emergency Power exercised? 2/yr under load, 10/yr w/o load
Duration? 4-6 hr under load, 1-2 hr w/o load

How often is the transfer switch exercised? 2/yr under load, 10/yr w/o load
Duration? 4-6 hr under load, 1-2 hr w/o load

Maintenance records of engine and generators kept Yes No

Maintenance records reviewed during inspection Yes No N/A

- Adequate? Yes No N/A

General Condition: Good Fair Poor

Comments:

A. VIRGINIA OPTIMIZATION PROGRAM REVIEW

Virginia Optimization Program Goal	Filter-months met		Improvement Shown?
	03/2019 to 2/2020	3/2018 to 2/2019	
Clarified Water Turbidity (use 'clarifier'-months) ≤ 1.0 NTU when average raw water turbidity ≤ 10.0 NTU ≤ 2.0 NTU when average raw water turbidity > 10.0 NTU	100% (48 of 48)	48 of 48	Optimal
Filtered Water Turbidity ≤ 0.3 NTU in 100% of readings	96.8% (245 of 253)	99.6% (253 of 254)	No
Filtered Water Turbidity ≤ 0.1 NTU in 95% of readings	99.6% (251 of 252)	99.6% (253 of 254)	No; near optimal
Filtered Water Turbidity peak ≤ 0.3 NTU in backwash recovery period for each backwash	99.6% (251 of 252)	96.5% (245 of 254)	Yes; near optimal
Backwash recovery period ≤ 15 minutes for each backwash	56% (141 of 252)	88.6% (225 of 254)	No; sig drop
Filtered Water Turbidity ≤ 0.1 NTU when filter returned to service after each backwash	91.7% (231 of 252)	81.1% (206 of 254)	Yes

Virginia Optimization Program Goal	Why is the VOP goal not met? What are the operator's plans to improve?
Clarified Water Turbidity	Note: DPU has not adopted clarifier goals because they have found meeting these goals does not produce the best water for filtration.
Filtered Water Turbidity ≤ 0.3 NTU in 100% of readings AND ≤ 0.1 NTU in 95% of filtered water readings	Plant has [REDACTED] operational trigger to take filter offline. Values above 0.3 NTU do not appear to happen often, may be blips that are captured in recording/instrumentation.
Filtered Water Turbidity peak ≤ 0.3 NTU in backwash recovery period for each backwash	The majority of excursions are due to a failure of the SCADA system to capture the actual operating data. WTP-wide SCADA improvements are almost completed.
Length of backwash recovery period ≤ 15 minutes for each backwash	Recovery period may point to issues getting below 0.1 NTU since not many instances of peaks above 0.3 NTU. Plant does appear to step backwash flow down prior to finishing backwash which some plants have seen as helpful. Other possible things to investigate is length of backwash (possibly too long), filter expansion impact on backwash, and if timing of recovery period is accurate. The recovery period is the time filter to waste is initiated to the time that turbidity falls below 0.10 NTU.
Filtered Water Turbidity ≤ 0.1 NTU when filter returned to service after each backwash	See above.

COMMENTS:

PART II - B RAW WATER SOURCE

(Shading Identifies a Potential Significant Deficiency)

A. RAW WATER INTAKE / SURFACE SOURCE EVALUATION

Source Name: James River, [REDACTED]

1. Intake located on: stream/free flowing river reservoir
2. Observed (visible) water quality: clear turbid¹ colored _____
 other _____
3. Activities or pollution sources in immediate intake area represent a potential health risk: Yes No
Describe: N/A
4. Observed conditions of surrounding area: Relatively undeveloped. Unchanged.
5. Reservoir level/stream flow: normal high¹ low
6. For in-stream intake:
check dam provided: Yes No
stream flow monitoring provided: Yes No
7. Condition of intake structure: Satisfactory
screen provided: [REDACTED]
condition of screen: good average poor
number of intake levels provided: none depths: n/a
drawoff depth/level being used: n/a
access provided to intake structure: Yes
method of cleaning screen: [REDACTED]
is it operable/used: Yes

8. Raw water pumps
number provided: [REDACTED] number operable: [REDACTED]
number in use: [REDACTED] pumping rate: 76.8 MGD (Daily total)
pump station subject to flooding: Yes No
protected against trespassing/vandalism: Yes No
access to pump station: Paved plant road

When were pumps etc. last maintained/checked? Major work 2009, monthly and other PM 5/17.
Pump [REDACTED] was rebuilt in 2018.

9. Treatment provided at intake (describe): [REDACTED]

10. Physical condition of intake: satisfactory needs attention

11. Capacity Evaluation
Intake components restrict ability of the waterworks to meet present demand? Yes No
Present water demand exceeds source safe yield? Yes No
Safe Yield: N/A Determination Date: N/A -- grandfathered allowance to withdraw water.
Present demand exceeds raw water pumping capacity? Yes No NA

Comments:
1. [REDACTED] estimated. For algae control.
2. Dredging of the basin is due and in planning stages.
2. The [REDACTED] will be replaced.

B. SOURCE WATER ASSESSMENT/PROTECTION

1. List land use activities of concern found but not listed in Zone 1 for the original source water assessment.

LUA TYPE	RISK	NAME OF PROPERTY OWNER	OWNER ADDRESS	LATITUDE/ LONGITUDE

2. Source Water Protection:

Does the waterworks have a written source water protection plan? Yes No

If "Yes":

Has the source water protection plan been submitted for review? Yes No NA

When was the last evaluation performed? _____

Has there been sufficient additional development in the watershed to warrant a revised source water protection plan? Yes No NA

If "No":

Has a schedule been established to develop a plan? Yes No

What is nature of watershed?

agricultural industrial forested residential

How is the watershed controlled/protected?

ordinances owned by waterworks zoning

other DEQ and other agencies

What is size of the watershed? Owner does not know and does not intend to find out.

Percent of watershed protected/controlled: Unknown %

Any sources of pollution in proximity of intakes: No response.

Discuss:

3. Does waterworks have a spill response plan? Yes No

Has it been tested? Yes No

4. Has there been a contamination event since last survey? Yes No

If "Yes", provide summary (date, source, materials and quantities involved, & effects on waterworks):

Comments: